

REACT Paragon

20261007
Art. 942428114

Content

Symbol key	1
Application area.....	2
General.....	2
The packaging contains	2
Protective equipment	2
Electrical safety	2
Handling	2
Installation	2

Dimensions and weights 3

Installation 4

Cutout dimensions.....	4
Suspension	5
Adjustment of grille coupling	7
Grille installation	8
Water connections.....	9
Air connection	11
Supply- and extract air	12

Commissioning..... 13

Air distribution.....	13
K-factor setting.....	14
Wiring diagram.....	15

Handling 16

Trouble shooting.....	16
Cleaning	16
Service/maintenance	16
Disposal.....	16
Product warranty	16

Recommendation for electrical installations .. 17

Maintenance..... 18

The document refers to product version "e".

Symbol key

Symbols on the machine

This product complies with applicable EU directives



Symbols in this user manual

Warning/Caution!



The document was originally written in Swedish

Application area

The product is a comfort module with continuous airflow control, equipped with functions for demand controlled indoor climate management. It is designed to provide ventilation, cooling and heating within the space.

The product may not be used for anything other than its intended use.

General



Read through the entire instructions for use before you install/use the product and save the instructions for future reference. It is not permissible to make changes or modify this product other than those specified in this document.

The packaging contains

1 x REACT Paragon

1 x Instructions for use

Protective equipment



Always use appropriate personal protective equipment for the work in question, in the form of gloves, respirators, protective glasses and helmets during handling, installation, cleaning and service/maintenance.

Electrical safety



Permitted voltage, see Electrical data.

It is not permissible to insert foreign objects into the product's contactor connections or ventilation openings; risk for short circuiting.

24 V isolation transformer to be connected should comply with the provisions of IEC 61558-1. Cable sizing must be carried out for cabling between the product and the power supply source.

Disconnect the power supply when working on products that are not required to run.

Always follow the local/national rules for who shall be permitted to carry out this type of electrical installation.

Handling

Always use appropriate transport and lifting devices when the product is to be handled to reduce ergonomic loads.

The product must be handled with care.


Installation

- Moist, cold and aggressive environments must be avoided.
- Assemble the product according to this instruction and applicable industry regulations.
- Install the product for easy access during service/maintenance.
- Avoid installing the product near a heat source.
- Check to make sure that the product does not have any visible defects.
- Check that the product is properly secured after it has been installed.
- Secure cables with cable ties.
- Check that all cables are properly secured in place after installation.

Dimensions and weights

REACT Paragon 800


Length (mm)	Type	Dim. (Ø)	Dry weight* (kg)		Water volume (l)	
			Without grille	With grille	Cooling	Heating
800 R	A	125	15.0	17.7	1.4	
800 L	A	125	15.0	17.7	1.4	
800 R	B	125	15.0	17.7	1.4	0.4
800 L	B	125	15.0	17.7	1.4	0.4
800 R	X	125	15.0	17.7	1.4	
800 L	X	125	15.0	17.7	1.4	



REACT Paragon 1100

Length (mm)	Type	Dim. (Ø)	Dry weight* (kg)		Water volume (l)	
			Without grille	With grille	Cooling	Heating
1100 R	A	125	20.0	23.4	1.9	
1100 L	A	125	20.0	23.4	1.9	
1100 R	B	125	20.0	23.4	1.9	0.5
1100 L	B	125	20.0	23.4	1.9	0.5
1100 R	X	125	20.0	23.4	1.9	
1100 L	X	125	20.0	23.4	1.9	

Dimensions with grille.



REACT Paragon 1400






Length (mm)	Type	Dim. (Ø)	Dry weight* (kg)		Water volume (l)	
			Without grille	With grille	Cooling	Heating
1400 R	A	125	23.2	27.6	2.5	
1400 L	A	125	23.2	27.6	2.5	
1400 R	B	125	23.2	27.6	2.5	0.7
1400 L	B	125	23.2	27.6	2.5	0.6
1400 R	X	125	23.2	27.6	2.5	
1400 L	X	125	23.2	27.6	2.5	

Dimensions without grille.


*Add 0.7 kg for control equipment.



Installation

Cutout dimensions




Suspension






Adjustment of grille coupling



Grille installation



Water connections


Connection dimensions

Standard design with factory fitted valves:

Length (mm)	Cooling, return	Heating, return
800, 1100, 1400	DN15 external thread	DN15 external thread

Standard design without factory fitted valves:

Length (mm)	Cooling, supply and return	Heating, supply and return
800, 1100, 1400	Plain pipe	Plain pipe
	(Cu) Ø 12 x 1.0 mm	(Cu) Ø 12 x 1.0 mm




Note that compression ring couplings require support sleeves inside the pipes.

Connecting the water


Connect the water pipes using push-on couplings or compression ring couplings

Please note that compression ring couplings require support sleeves to be fitted inside the pipes. Do not use soldered fittings when connecting the water pipes. High temperatures may damage the product's existing soldered joints.




Water connection on right side (R)

Cooling and heating R, all sizes.



Cooling R, all sizes.




Water connection on right side.


A1 = Cooling water, supply
A2 = Cooling water, return
B1 = Heating water, supply
B2 = Heating water, return

Water connection on left side (L)

Cooling and heating L, all sizes.




Cooling L, all sizes.



Water connection on left side

A1 = Cooling water, supply
A2 = Cooling water, return
B1 = Heating water, supply
B2 = Heating water, return

Water connection on back side (WB)



Water connection on back side.

A1 = Cooling water, supply

A2 = Cooling water, return

B1 = Heating water, supply


B2 = Heating water, return

Water quality

Swegon recommends water quality according to VDI 2035-2 for both the heating and cooling systems. In order to maintain the oxygen content in the water below the levels (<0.1 mg/l) prescribed in VDI 2035-2, it is recommended to install a vacuum degasser, particularly in the cooling system where it's more challenging to dissolve gas. It is also important that the prepressure in the expansion vessel is dimensioned according to EN-12828 for both the heating and cooling systems and that regular checks are made of the pre-pressure. The cooling and heating systems must be designed to prevent oxygen from entering the system, this is particularly important to consider when selecting flex hose, pipes and expansion vessels. When the system is filled with fresh water, it has an oxygen content of approximately 8 mg/l, however, this oxygen is consumed quickly through corrosion processes and within a few days the oxygen in the water should be consumed. Nevertheless, it is important to avoid filling the system with fresh water unnecessarily.

Automatic deaerators are often installed to facilitate filling of the system. It is recommended that the automatic deaerators are turned off once the system has been fully vented to avoid these drawing in air in the system if the pre-pressure in the expansion vessel should drop.

Water connection, CCO valve



Water connection, CCO valve.

A1 = Cooling water, supply

A2 = Cooling water, return

B1 = Heating water, supply

B2 = Heating water, return

C = CCO valve

D = Flexible hose


Air connection

All designs have an air connection Ø125.




The standard design has the air connection centered on the back of the product for easy access from both ends and back.

The suite variant, which is only available in length 1400 mm, has two parallel air connections on the back (2x Ø125)

Standard design, view from the back:



Suite design, view from the back:




Connection dimensions




Design	Length (mm)	Air connection	
		1 x Ø125	2 x Ø125
1: Standard	800, 1100, 1400	Yes	No
2: Suite	1400	No	Yes

Supply- and extract air

Supply air kit




Extract air kit




Commissioning


Air distribution



Horizontal air distribution with ADC



Vertical air distribution with adjustable lamellas in the supply air grille.



ADC.

K-factor setting

REACT Paragon continuously regulates the k-factor to ensure the required airflow is maintained. The active k-factor setpoint can be found on the k-factor label mounted at the actuator.

Control measurement of the airflow

Step 1

Allow the system to stabilize. It is recommended to set the system to balancing mode and wait until the products have stabilized and the expected airflow is reported.

Step 2

Disconnect the RJ45 cable from the motor control board to prevent the product from adjusting itself during the control measurement.

Step 3

Disconnect the pressure tubes from the air hose fittings and connect the measuring instrument to measure the duct pressure.

Step 4

Read the product's current K-factor by checking the K-factor scale against the control plate.

Step 5


Use the measured pressure and the current K-factor to calculate the airflow (l/s) using the formula:

$$q = k \cdot \sqrt{p}$$

$$q = 3 \cdot \sqrt{100}$$

$$q = 30 \text{ l/s}$$

Example showing the K-factor is 3.




RJ45 cable.


Wiring diagram

Wiring diagram for REACT Paragon ordered with and without accessories

When REACT Paragon is ordered with accessories, the product is delivered with a terminal block. The cable from the motor controller to the motor (A) is already connected, as is the cable (B) from the motor controller to the terminal block. Other accessories are connected to the terminal block according to the instructions below.



When REACT Paragon is ordered without accessories, the product is delivered without a terminal block but with cable (A) pre-mounted from the motor controller to the motor, as well as the cable mounted on the motor controller for further on-site connection.



Connection – motor controller

- Blue - Control signal (Y) 0..10/(2..10) V
- Orange - Feedback signal (U) 0..10/(2..10) V*
- Red – Modbus (B)**
- Green – Modbus (A)**
- Brown – 24V AC/DC
- White – 0V/GND***

*Load on U (feedback): max 5 mA.

To prevent signal reflections and ensure stable Modbus RTU communication, a **120 Ω (1/4 W) termination resistor must be connected across the communication line at both ends of the bus.

Connect the 120 Ω termination resistor in parallel directly between terminals **A** and **B** on the first and last node in the loop.

***0V/GND for the power supply serves as the reference level for both the analog interface and the Modbus interface.

Electrical data

Power supply	24V AC +-15 % 50-60Hz 24V DC +-25 %	
Power consumption	VA unit	W / unit
Inrush current 10 ms/20 ms	72	36
Operation	4.5	3

Handling

Trouble shooting

The product does not communicate over Modbus

- Make sure that the product is energised.
- Check the product's Modbus connection.
- Check the product's communication settings.
- Check that the product has the right and unique Modbus address.

The product shows incorrect/no airflow

- Make sure that the product is energised.
- Check that the motor's set size (Vnom) corresponds with the physical size of the product.
- Make sure that the product is installed according to the recommended distance to disruptions.
- Check that there is an airflow in the system.
- Make sure that the product is correctly oriented in terms of air direction. The airflow must follow the instructions on the product.
- Check that the measuring tubes are mounted correctly, plus to plus (red), minus to minus (blue).
- Check that the measuring tubes are undamaged and not creased.

The product does not regulate the airflow

- Make sure that the product is energised.
- Check that the product is connected correctly.
- Check that the product is not force controlled.

The product does not regulate on the desired airflow

- Check that the settings for Vmin and Vmax correspond with the required regulation range.
- Check the electrical connection for the required function, see *Wiring diagram*.

Product does not exit test mode

- Check that the product is connected correctly, check the "Y" signal and polarity on "G" and "GO". See *Wiring diagram*.
- Check setpoint settings for Vmin and Vmax. The value of Vmax must be higher than Vmin for the product to be in automatic mode.

Cleaning

Ideally the product should be cleaned twice a year by vacuuming the coil to remove loose dust.

In fibre dense environments as hotels and ward rooms a first vacuuming after three months is recommended and thereafter an interval of 1-2 times a year. This is due to the fact that new textiles often loose a lot of fibres in the beginning of their life cycle.

A simple visual inspection of connections is recommended when cleaning.

On painted surfaces such as grills: Avoid aggressive cleaning agents which may harm the surface. Normally a mild soap or alcohol solution is fully adequate. See *Maintenance*.

Cleaning of electrical components

- If needed, use a dry cloth to clean the components.
- Never use water, detergent and cleaning solvent or a vacuum cleaner.

Service/maintenance

- In connection with a service, mandatory ventilation inspection or cleaning of the ventilation system, check that the general condition of the products looks ok. Pay particular attention to the suspension, cables and that they sit firmly in place.
- It is not permissible to open or repair electrical components.
- If you suspect that the product or a component is defective, please contact Swegon.
- A defective product or component must be replaced by an original spare part from Swegon.

Disposal

Help protect the environment by handling packaging materials responsibly and using products in compliance with applicable environmental regulations.

Product warranty

The product warranty or service agreement will not be in effect/will not be extended if: (1) The product is repaired, modified or changed, unless such repair, modification or change has been approved by Swegon AB; or (2) the serial number on the product has been made illegible or is missing.

Recommendation for electrical installations

- Swegon recommends that all electrical installations are carried out by a qualified electrician.
- Swegon recommends that a 24 V power supply is connected with a 1.5 mm² copper cable to minimise the risk of voltage drops in the case of long cable runs.
- Swegon recommends the use of Swegon-labelled transformers for the power supply of Swegon products.

Voltage drop table at different loads (amperes) with a 1.5 mm² cable

Metres (m)	Current/Amperes					
	1	2	3	4	5	6
10	0.24	0.48	0.72	0.96	1.20	1.44
20	0.48	0.96	1.44	1.91	2.39	2.87
30	0.72	1.44	2.15	2.87	3.59	4.31
40	0.96	1.91	2.87	3.83	4.78	5.74
50	1.20	2.39	3.59	4.78	5.98	7.18
60	1.44	2.87	4.31	5.74	7.18	8.61
70	1.67	3.35	5.02	6.70	8.37	10.05
80	1.91	3.83	5.74	7.65	9.57	11.48
150	3.59	7.18	10.76	14.35	17.94	21.53
160	3.83	7.65	11.48	15.31	19.13	22.96

The largest permitted voltage drop is 3.6 V.

Description of problem:

Swegon's electrical units and machines are designed to work within specific voltage intervals. If the voltage drops below the nominal value, this can lead to impaired performance or even damage to the equipment.

Voltage drops also entail increased resistance in cables and components, which generates heat. This heat represents a loss of electrical energy. Depending on the voltage drop, the energy losses can be significant.

A general guideline for a 24 V system is that a 15% voltage drop is acceptable (3.6 volts).

How is the voltage drop in the cable calculated:

Resistance (R) = (Resistivity (p) x Length (L)) / Area (a).


Voltage drop in wire (UL) = Resistance (R) x current (I)

$$R_1 = \frac{p \cdot L}{a}$$

$$R_2 = \frac{p \cdot L}{a}$$

$$R = R_1 + R_2$$

$$UL = R \cdot I$$



For example, the resistivity for copper is 0.0175 ohm mm²/m at 15°C. Bear in mind that the resistance increases by 0.4% per degree Celsius.

Examples of voltage drops in cables:

Input data	Value	Unit
Supply voltage	24	Volts
Current (load)	1.25	Amperes
Cable area	1.5	mm
Cable length (phase + neutral wire)	50	m

Voltage drop	1.5	Volts
--------------	-----	-------

Example 1 at 22°C.

Input data	Value	Unit
Supply voltage	24	Volts
Current (load)	1.25	Amperes
Cable area	1.5	mm
Cable length (phase + neutral wire)	200	m

Voltage drop	6	Volts
--------------	---	-------

Example 2 at 22°C.

Maintenance

