

Reversible heat pump GOLD RX/HC Cooling unit GOLD RX/C Installation and Maintenance Instructions Sizes 011-080

GOLD RX/HC, GOLD RX/C




1. Safety Instructions	3
1.1 Safety isolating switch/Main switch	3
1.2 Risks	3
1.3 Electrical equipment.....	3
1.4 Authorisation.....	3
1.5 Decals.....	3
2. Overview	4
2.1 General.....	4
2.2 Basic function diagram	5
2.2.1 Size 011-030	5
2.2.2 Size 035	6
2.2.1 Size 040-080	7
3. Installation.....	8
3.1 Legal requirements.....	8
3.2 Unloading/site transport.....	9
3.3 Arrangement	9
3.4 Basic installation principle.....	9
3.4.1 Height adaptation/water trap installation	9
3.4.2 Splitting/Installation of air handling unit sections.....	10
3.4.3 Internal electric wiring RX/HC, RX/C with split refrigerant circuit.....	12
4. Power connection	13
5. Commissioning / Calibration	15
5.1 General	15
5.2 Phase-sequence monitor	15
5.3 Actions if incorrect phase-sequence	15
6. Alarms	15
7 Maintenance.....	16
7.1 Cleaning	16
7.2 Handling of refrigerant.....	16
7.3 Leakage tracing interval/Obligation to report	16
7.4 Service	16
8. Trouble shooting and leakage tracing .	17
8.1 Troubleshooting Schedule	17
8.2 Leakage Tracing	17
9. Dimensions	18
10. General technical data	23
11. Wiring diagram	23
12. Declaration of Conformity.....	23


1. SAFETY INSTRUCTIONS

1.1 Safety isolating switch/Main switch

The connection hood for RX/HC and RX/C 011-020 is placed on top of the air handling unit to the right or left of the GOLD air handling unit's connection hood (above the rotating heat exchanger), see illustration. The safety isolating switch is located on the side of the connection hood for RX/HC and RX/C size 011-020.



For size 025-080, the safety isolating switch is located on the air handling unit's inspection side to the right or left of the GOLD air handling unit's safety isolating switch (in front of rotating heat exchanger), see illustration.



The safety switch should not be used to start or stop of the reversible heat pump.

Ensure that the RX/HC alt. RX/C is shut off by stopping the air handling unit or by temporarily shutting off the RX/HC alt. RX/C via the hand-held micro terminal, see the GOLD operation and maintenance instructions.

When this has been carried out, the current can be isolated with the safety switch. The safety switch must be switched off in order to make it possible to open the inspection door.

Important:

Always switch off the safety isolating switch before servicing the unit if not otherwise specified in the pertinent instructions.

1.2 Risks

Warning

Before carrying out any work, make sure that the power supply to the air handling unit has been switched off.

Warning

Under no circumstances may the refrigerant circuit be opened by unauthorised personnel, since it contains gas under high pressure.

Risk areas for refrigerant

Risk area for refrigerant is in principal inside the entire reversible heat pump. For handling when leakage, see section 7.2.

The refrigerant used is R410A.

Warning

The inspection doors must not be opened when air handling unit is operational. The doors can open and injure personnel.

1.3 Electrical equipment

Housed on the inside of an inspection door to the right or left of the rotating heat exchanger is electrical equipment for RX/HC alt. RX/C mounted in a separate electrical equipment cubicle.

1.4 Authorisation

Only authorized electricians shall be permitted to install electrical wiring in the unit.

Only an accredited refrigeration company shall be permitted to modify or repair the refrigeration circuit.

Other service work in the unit should only be performed by service personnel trained by Swegon.

1.5 Decals

The type number mark with type designation, serial number, refrigerant volume and more is affixed on the cooling unit's door.

2. OVERVIEW

2.1 General

General

RX/HC is a complete reversible heat pump, fully integrated in the GOLD air handling unit.

RX/C is a complete cooling unit, fully integrated in the GOLD air handling unit.

Note: On the following pages, the air handling unit is always referred to as RX/HC, even though the function in the supplied unit is RX/C. In those cases where differences exist, this is specified in the text.

RX/HC consists of one section with sorption rotor and one section on each side of this that contains heating/cooling engineering components.

All components from a cooling and electrical standpoint are pre-wired.

The evaporator and condenser consist of copper tubes and profiled aluminium fins.

RX/HC is test run prior to delivery.

RX/HC is available in 6 physical sizes, designed for GOLD air handling units in size 011-080.

RX/HC are designed and tested for ambient temperatures from -40°C to +40°C. The heat pump function withstands temperatures from -25°C to +35°C.

Compressors

The refrigerant circuit contains a variable speed controlled compressor (all sizes) that regulates the output. Size 040-080 also comprises an on/off compressor for increased capacity.

Completely direct-acting system

The RX/HC has a completely direct-acting system. It has an evaporation coil for direct-evaporating refrigerant on the cold side and a condenser coil on the hot side.

Refrigerant

Type R410A refrigerant is used. The refrigerant circuits are charged with refrigerant on delivery. At present, this refrigerant has no known influence on the ozone layer.

Refrigerant volume

See section 10. General technical data.

Installation check/Obligation to report/Leakage tracing interval


Must be carried out according to the F-Gas Regulation EU/2024/573 and associated local legislation. See also Section 3.1.

Quality System to ISO 9001 and Environmental Management System to ISO 14001

Swegon AB works to a certified quality system that conforms to ISO 9001 standard and a certified Environmental Management System that conforms to ISO 14001.

2.2 Basic function diagram


2.2.1 Size 011-030



SPH	High pressure switch	07	Shut-off valve
BPH	High pressure sensor	08	Connection, service
BPL	Low pressure sensor	09	Drying filter
BT5X	Sensor, electronic expansion valve	10	Sight glass
01	Compressor	12	4-way valve
02	Condenser (exhaust air) (Evaporator for heating operations, not RX/C)	13	Non-return valve
03	Evaporator (supply air) (Condenser for heating operations, not RX/C)	14	Buffer tank
06	Electronic expansion valve	19	Safety valve
		20	LP, service outlet in RX section
		21	HP, service outlet in RX section

For a description of the control functionality, see the function guide reversible heat pump RX/IHC or function guide cooling unit RX/C.

2.2.2 Size 035




SPH	High pressure switch
BPH	High pressure sensor
BPL	Low pressure sensor
BT5X	Sensor, electronic expansion valve
01	Compressor
02	Condenser (exhaust air) (Evaporator for heating operations, not RX/C)
03	Evaporator (supply air) (Condenser for heating operations, not RX/C)
06	Electronic expansion valve

07	Shut-off valve
08	Connection, service
09	Drying filter
10	Sight glass
12	4-way valve
13	Non-return valve
14	Buffer tank
19	Safety valve
20	LP, service outlet in RX section
21	HP, service outlet in RX section
23	Solenoid valve

For a description of the control functionality, see the function guide reversible heat pump RX/HC or function guide cooling unit RX/C.

2.2.1 Size 040-080



SPH	High pressure switch	07	Shut-off valve
BPH	High pressure sensor	08	Connection, service
BPL	Low pressure sensor	09	Drying filter
BT5X	Sensor, electronic expansion valve	10	Sight glass
01	Compressor	12	4-way valve
02	Condenser (exhaust air) (Evaporator for heating operations, not RX/C)	13	Non-return valve
03	Evaporator (supply air) (Condenser for heating operations, not RX/C)	14	Buffer tank
06	Electronic expansion valve	19	Safety valve
		20	LP, service outlet in RX section
		21	HP, service outlet in RX section
		23	Solenoid valve

For a description of the control functionality, see the function guide reversible heat pump RX/IHC or function guide cooling unit RX/IC.

3. INSTALLATION

3.1 Legal requirements

This product relies on the fluorinated gas R410A as the refrigerant. It is known as a greenhouse gas because it contributes to the global warming if released to the atmosphere.

The European Union is committed to reducing emissions of such gases and Regulation EU/2024/573 (F-Gas) must be complied with.

Ensure that you are fully aware of your local regulations and that they are complied with.

The global warming potential (GWP) of greenhouse gases is expressed in equivalent mass of CO₂. R410A has a GWP of 2088 as per IPCC AR4.

The F-Gas regulation requires that all steps are taken to eliminate the release of greenhouse gases to the atmosphere. This product is designed and manufactured in accordance with Regulation EU/2024/573. Capped valves and capped service ports allow proper repair or disposal. The product is leak tested in the factory in accordance with EN 378-2.

If the installation in which this product shall be installed will have a total quantity of green house gas with a total GWP equivalent to 14 tonnes then it must be reported to the relevant authority. This is the responsibility of the operator and must be done prior to the installation.

Regulation EU/2024/573 requires that this product is leak tested periodically. Details are given in the table below. The product shall be leak tested after installation and prior to start-up.

Leak testing and any other service work on the refrigerant circuit must be carried out by an authorised person with the necessary training and certification in accordance with Regulation EU/2024/573.

Note that the Regulations governing refrigerants and their use are subject to change and it is important to follow the latest editions.

Table

Unit	Refrigerant (kg)	Ton CO ₂ e
GOLD RX/HC 011	6	12,53
GOLD RX/HC 012/014	8	16,7
GOLD RX/HC 020/025	10	20,88
GOLD RX/HC 030	13	27,14
GOLD RX/HC 035	15	31,32
GOLD RX/HC 040	17,5	36,54
GOLD RX/HC 050	17,5	36,54
GOLD RX/HC 060	20	41,76
GOLD RX/HC 070	25	52,2
GOLD RX/HC 080	30	62,64

Leakage warning system not installed

3.2 Unloading/site transport


See the Installation Instructions for the GOLD air handling unit.

3.3 Arrangement

See the Installation Instructions for the GOLD air handling unit.

3.4 Basic installation principle

GOLD RX/HC 011-080



¹⁾ Connection hood, only size 011-020.

²⁾ Electric air heater for defrosting (accessory not RX/C).

³⁾ Air recirculation section RX/HC (accessory not RX/C).

3.4.1 Height adaptation/water trap installation

For reversible heat pump RX/HC, the drainage pipes to the evaporator/condenser must each be fitted with a water trap (accessory). For cooling unit RX/C, the drainage pipe to the condenser must be plugged and the drainage pipe to the evaporator fitted with a water trap (accessory).

The air handling unit must be raised by at least 50 mm to provide space for the water trap on the lower level. Adjustable support feet (accessory) can be appropriately fitted to the base beams for this purpose.

3.4.2 Splitting/Installation of air handling unit sections

RH/HC with factory-fitted refrigerant circuit

For separation/installation to other air handling unit sections, see the separate installation instructions for GOLD.

RX/HC with factory-fitted refrigerant circuit that is split and finally installed on site

Filter/fan sections and heat exchanger section

The installation's filter/fan sections and the heat exchanger section are supplied assembled to varying degrees, depending on the size of the installation. The heat exchanger section and fan/filter section must be split, see the separate installation instructions for GOLD.

Place the heat exchanger section in the intended location and remove the cover panels from the rear of the section (torx screws).

Section with exhaust coil and section with compressor/supply air coil

RX/HC with split refrigerant circuit is supplied with section with exhaust coil and section with compressor/supply air coil assembled. The sections must be split, see below and the next page.

RX/HC is prefilled with refrigerant.

All the cover panels at the rear of the section with exhaust coil and the section with compressor/supply air coil must be removed (torx screws) to gain access for continued work.

Note: The sections must not be transported when the cover panels are removed.


Note:
The work below may only be performed by certified refrigeration technicians.

There are lead-throughs in the upper level of the heat exchanger section for supply air in the lower level. There are lead-throughs in the lower level of the heat exchanger section for supply air in the upper level. See the illustration to the right.


There are four refrigerant pipes (of which two to the sub-cooling circuit) in the section with exhaust coil and the section with compressor/supply air coil. There are connector pipes and new gaskets supplied in some of the these sections.

The connector pipes are packed together with the compressor section and in pre-cut lengths with a screw connection.

The screw connection is available without or without a flange, see the illustration to the right.



The illustration shows RX/HC as seen from the back in an air handling unit with supply air in the upper level. The refrigerant pipes are placed in the upper level with supply air in the lower upper level, see dashed lines.



Screw connection with flange



Screw connection without flange

1. Close the shut-off valves (8 pcs.), see the illustration to the right. The location can vary depending on the size/variant, although the principle is always the same.
2. Refrigerant from pipes between shut-off valves is utilised and filled in the compressor section by the buffer tank.
3. Disconnect pipe joints and screws holding the two sections together (see also the separate installation instructions for GOLD).
4. Disconnect cable to drip tray heating in junction box, see section 3.4.3.
5. The section with exhaust coil and the section with compressor/supply air coil are placed on either side of the section with the rotary heat exchanger. The sections are assembled (see also the separate installation instructions for GOLD).
6. Relevant cover plates (2 pcs.) for pipe lead-throughs in the heat exchanger section are removed, see the illustration to the right.
7. Assemble the connector pipes with new gaskets and the correct tightening torque according to the table below. It is important that the gasket is centred precisely to ensure that it seals tightly.

Screw connection without flange


Lubricate the unthreaded pipe end where it will come into contact with the swivelling nut. Apply suitable thread sealant on the threaded pipe end. Use a counterhold when tightening.

Screw connection with flange


Tighten the screws crosswise.

Pipe diameter (mm)	Tightening torque (Nm)
10	20 - 25 Nm
12	34 - 47 Nm
16	54 - 75 Nm
18	68 - 71 Nm
22	25 Nm
28	25 Nm
35	50 Nm
42	50 Nm


8. The supplied split cover plates are installed around the pipes on both sides in the heat exchanger section, see the illustration to the right.
9. Open the shut-off valves (8 pcs.).
10. Leakage tracing must be performed.
11. Supplied pipe insulation is cut and installed.
12. Filter/fan sections are placed in the correct location and assembled with other sections, see the separate installation instructions for GOLD.



Shut-off valve (8 pcs.)



Cover plates for pipe lead-through.
Two cover plates are removed, either in the lower level or the upper level, depending on the variant.



Split cover plates for pipe lead-through.
Assemble the inner cover plate first, making sure that the seals are correctly positioned.


3.4.3 Internal electric wiring RX/HC, RX/C with split refrigerant circuit

When RX/HC with split refrigerant circuit is assembled, internal wiring must be performed, see the illustration below.

Cable to sensor is connected to the control card on the connection marked Sensor 3

Cable to any electric air heater is connected to the I/O module on the connection marked Heat/Cool


Cable to sensor is connected to the control card on the connection marked Sensor 4



Cable to any electric air heater is connected to terminal block marked QMR and earth, see the illustration below

Cable is connected to the control card on the connection marked Com4

Cable to drip tray heating is reconnected to the junction box (dismantled before splitting the section with exhaust coil and the section with compressor/supply air coil, see section 3.4.2)



4. POWER CONNECTION

The cross-sectional dimension of the power supply cable should take into consideration the ambient temperature and way the cable is run.

Cables must be routed safely. Make sure that the cables do not touch components, since surfaces could be hot or vibrate.

The connection of RX/HC is shown here. For the connection of the GOLD air handling unit, see the installation instruction GOLD.

Important:

Installation must be carried out by a authorised electrician.



Size 011-020

Dismantle the connection hood to RX/HC.

Connect the incoming power supply to the safety switch, see the illustration.

5-core system, 400 V $\pm 10\%$. Also see section 10 Technical data.

Possible locations of the connection hood RX/HC



Size 025-080

Open the inspection door in front of the electrical equipment cubicle.


Open the cover on the electrical equipment cubicle.

The incoming power supply is routed through the cable entry on the upper cover panel by the **electrical equipment cubicle on the upper level** and on to the safety switch block in the electric equipment cubicle.

At **electrical equipment cubicle on the lower level**, open the inspection door above the electrical equipment cubicle. The incoming power supply is routed through the cable entry on the upper cover panel, down to the cable entries on the rear of the electrical equipment cubicle and on to the safety switch block in the electric equipment cubicle.


The cable entries on the back of the electrical equipment cubicle are accessible by opening the inspection door on the closest air handling unit section.

Possible locations of the safety isolating switch RXIHC



Electrical equipment cubicle on the upper level


Inspection door in front of the electrical equipment cubicle.




Connect the incoming power supply to the safety switch block. The wiring terminal for incoming earth is situated right next to the safety switch.

5-core system, 400 V $\pm 10\%$. Also see section 10 Technical data.

Electrical equipment cubicle on the lower level



Safety switch block.



5. COMMISSIONING / CALIBRATION

5.1 General

Commissioning is performed according to the ordinary commissioning for GOLD RX, see the separate Operation and Maintenance Instructions.

Calibration of defrosting parameters is performed at the factory before delivery.

Recalibration may be necessary in the following instances:
Replacement of the GOLD air handling unit's control card IQlogic.

The exhaust air coil is modified or deformed.

The exhaust air coil has a surface coating that is considered small enough not to be rectified.

Other suspicions of erroneous calibration.


It is important during calibration that the coil is dry and the airflow is unaffected.

5.2 Phase-sequence monitor

GOLD RX/HC size 040 - 080 is equipped with a phase sequence monitor for compressors.

The phase sequence monitor is installed in the electrical equipment cubicle for RX/HC, see section 4 for the location of the electrical equipment cubicle.

Alarm no. 70:12 is initiated if an incorrect phase sequence is detected.



LED on = phase sequence correct.
LED flashes = fault indication.

5.3 Actions if incorrect phase-sequence

Warning

May only be performed by a qualified electrician or trained service personnel.

- Stop GOLD RX/HC on the handheld terminal.
- Set the safety switch to position OFF on RX/HC.
- Isolate the power supply to RX/HC.

Important:

Check that the incoming power supply to RX/HC is off by measuring.

- Switch two phases on the incoming power supply cable in order to obtain the correct phase sequence (direction of rotation).
- Connect the power supply to RX/HC.
- Set the safety switch on RX/HC to ON.
- Start GOLD RX/HC, see section 5.1.

6. ALARMS

For a description of the alarms, see the GOLD Manual for Alarms and Information Messages.

7 MAINTENANCE

7.1 Cleaning

If needed, clean the inside cleaning of the unit by vacuum cleaning and wiping surfaces with a damp cloth. Inspections should be performed twice a year.

7.2 Handling of refrigerant

The refrigerant used is R410A.

The refrigerant circuit is completely charged when the unit is delivered.

Warning

Under no circumstances may the refrigerant circuit be opened by unauthorised personnel, since it contains gas under high pressure. Only an accredited refrigeration company shall be permitted to modify or repair the refrigeration circuit.

RX/HC is equipped with a safety valve to prevent excessively high pressure in the system caused by e.g. a fire.

Important:

Contact Swegon Teknik in the event of leakage of refrigerant.

Warning

If refrigerant is exposed to fire or in some other way becomes superheated in the atmosphere, poisonous gases can form.

Important:

Filling of refrigerant must be performed in accordance with the recommendations of the refrigerant manufacturer.

Avoid direct skin contact with refrigerant and lubricant.

Use tightly sitting protective glasses, protective gloves and covering work clothes.

Arrange ventilation/point extraction.

In the event of eye contact

rinse the eyes using an eye-wash shower (or with lukewarm water) for 20 minutes. seek a doctor.

In the event of contact with skin

carefully wash with soap and lukewarm water.

In the event of frostbite

seek a doctor.

7.3 Leakage tracing interval/ Obligation to report

Must be carried out according to the F-Gas Regulation EU/2024/573 and associated local legislation.

7.4 Service

Only service personnel trained by Swegon should be permitted to modify the cooling unit.

8. TROUBLE SHOOTING AND LEAK-AGE TRACING

8.1 Troubleshooting Schedule

Symptoms	Possible cause	Action
Compressor is not operating	The voltage has been isolated. Incorrect phase sequence. The compressor safety circuit has been broken. Defective compressor.	Check the operating/safety switch. Check the condition of the fuses. Check and change the phase sequence. Check, reset if needed. Replace the compressor.
Too low capacity	Leakage, inadequate refrigerant. The voltage has been isolated. No air flow or too low air flow across the evaporator. Thermostat/Control equipment incorrectly set or defective.	Leak test, fill with refrigerant if necessary. Check the operating/safety switch. Check the condition of the fuses. Check the air flow. Adjust the setting or replace faulty components.
The compressor switches off because the low pressure sensor has measured an excessively low value.	Inadequate refrigerant. No air flow or too low air flow across the evaporator. The expansion valve is defective. The low pressure switch is defective.	The cooling system is leaking. Tighten the leak and charge with refrigerant. Check the airflow. Check, replace. Check, replace.
The compressor switches off because the high pressure sensor has measured an excessively high value.	No air flow or too low air flow across the condenser. Excessively high exhaust air temperature. The high pressure sensor is defective.	Check the air flow. Check the exhaust air temperature. Check, replace.
Significant freezing on the evaporator.	The expansion valve is defective or incorrectly set. No air flow or too low air flow across the evaporator.	Check. Replace or adjust setting. Check the air flow.

8.2 Leakage Tracing

Leakage tracing should be carried out at least once per year as a precaution. The leakage tracing inspection must be documented.

If the system is leaking, this will become apparent firstly by impaired performance, or if the leakage is substantial, when the system does not operate at all.

If you suspect that the cooling system is leaking refrigerant, check the level of refrigerant in the sight glass located on the heating circuit's electrical equipment cubicle.


If you see continuous and a substantial amount of bubbling in the sight glass and the reversible heat pump operates at appreciably lower capacity than normal, the system is probably leaking. One or several bubbles appearing when the cooling unit is started up, operation at reduced capacity or normal operation need not necessarily indicate a refrigerant deficiency.

If it is bubbling in the sight glass and the cooling unit operates at appreciably lower capacity, call for qualified service help.

NOTE! Maintenance work in the refrigerant system is permitted to be carried out only by an accredited inspectorate (a company with requisite authorisation).

9. DIMENSIONS

RX/HC 011/012



The illustration shows RX/HC integrated in a GOLD standard air handling unit set-up.

The installation length for RX/HC corresponds to the E-measurement.


Placement of the air handling unit sections, duct connections, connection hood, drain pipe, etc. may vary depending on the selected variant.

* The air handling unit is supplied without end connection panel if a duct accessory housed in an insulated casing will be connected.

The AHU can also be supplied with full face end connection panel (accessory).

Size	A	B	C	D	E	F	G	H	J	K	L	Ø	Weight, kg
011	647	1199	324	565	1695	324	647	1295	953	551	2989	500	737-845
012	647	1199	324	565	1695	324	647	1295	953	551	2989	500	765-879

RX/HC Top 011/012




The illustration shows RX/HC integrated in a GOLD standard air handling unit set-up.

The installation length for RX/HC corresponds to the E-measurement.

Placement of the air handling unit sections, duct connections, connection hood, drain pipe, etc. may vary depending on the selected variant.

Size	A	B	D	E	F	G	H	I	J	L	Ø	Weight, kg
011	827	1199	565	1695	332	500	1295	332	953	3349	500	837-867
012	827	1199	565	1695	332	500	1295	332	953	3349	500	865-901

RX/HC 014/020



The illustration shows RX/HC integrated in a GOLD standard air handling unit set-up.

The installation length for RX/HC corresponds to the C-measurement.


Placement of the air handling unit sections, duct connections, connection hood, drain pipe, etc. may vary depending on the selected variant.

* The air handling unit is supplied without end connection panel if a duct accessory housed in an insulated casing will be connected.

The AHU can also be supplied with full face end connection panel (accessory).

Size	A	B	C	D	E	F	G	H	I	J	K	L	M	Weight, kg
014	757,5	1400	1695	565	205	400	1000	1551	375	1154	200	3210	188	934-1074
020	757,5	1400	1695	565	205	400	1000	1551	375	1154	200	3210	188	964-1124

RX/HC Top 014/020




The illustration shows RX/HC integrated in a GOLD standard air handling unit set-up.

The installation length for RX/HC corresponds to the C-measurement.

Placement of the air handling unit sections, connection hood, drain pipe, etc. may vary depending on the selected variant.

Size	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Weight, kg
014	1039	1400	1695	565	120	400	1000	1551	106	1154	165	3773	300	1200	200	100	1088-1156
020	1039	1400	1695	565	120	400	1000	1551	106	1154	165	3773	300	1200	200	100	1118-1210

RX/HC 025/030



The illustration shows RX/HC integrated in a GOLD standard air handling unit set-up.

The installation length for RX/HC corresponds to the C-measurement.


Placement of the air handling unit sections, duct connections, connection hood, drain pipe, etc. may vary depending on the selected variant.

* The air handling unit is supplied without end connection panel if a duct accessory housed in an insulated casing will be connected.

The AHU can also be supplied with full face end connection panel (accessory).

Size	A	B	C	D	E	F	G	H	I	J	K	L	M	Weight, kg
025	848	1600	1695	565	200	500	1200	1811	405	1354	200	3391	203	1238-1445
030	848	1600	1695	565	200	500	1200	1811	405	1354	200	3391	203	1300-1479

RX/HC Top 025/030




The illustration shows RX/HC integrated in a GOLD standard air handling unit set-up.

The installation length for RX/HC corresponds to the C-measurement.

Placement of the air handling unit sections, connection hood, drain pipe, etc. may vary depending on the selected variant.

Size	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Weight, kg
025	1039	1600	1695	565	120	400	1200	1811	106	1354	165	3773	300	1400	200	100	1378-1507
030	1039	1600	1695	565	120	400	1200	1811	106	1354	165	3773	300	1400	200	100	1440-1541

RX/HC 035/040




The illustration shows RX/HC integrated in a GOLD standard air handling unit set-up.
The installation length for RX/HC corresponds to the C-measurement.
Placement of the air handling unit sections, duct connections, connection hood, drain pipe, etc. may vary depending on the selected variant.

* The air handling unit is supplied without end connection panel if a duct accessory housed in an insulated casing will be connected.
The AHU can also be supplied with full face end connection panel (accessory).

Size	A	B	C	D	E	F	G	H	I	J	K	L	M	Weight, kg
035	1038.5	1990	1695	565	245	600	1400	2159	479	1744	295	3772	240	1664-1922
040	1038.5	1990	1695	565	245	600	1400	2159	479	1744	295	3772	240	1740-2016

RX/HC 050/060




The illustration shows RX/HC integrated in a GOLD standard air handling unit set-up.
The installation length for RX/HC corresponds to the C-measurement.
Placement of the air handling unit sections, connection hood, drain pipe, etc. may vary depending on the selected variant.

* The air handling unit is supplied without end connection panel if a duct accessory housed in an insulated casing will be connected.
The AHU can also be supplied with full face end connection panel (accessory).

Size	A	B	C	D	E	F	G	H	I	J	K	L	M	Weight, kg
050	1038.5	2318	1815	565	145	800	1600	2288	344	625	359	3892	172	2138-2445
060	1038.5	2318	1815	565	145	800	1600	2288	344	625	359	3892	172	2322-2611

RX/HC 070/080



The illustration shows RX/HC integrated in a GOLD standard air handling unit set-up.
The installation length for RX/HC corresponds to the C-measurement.
Placement of the air handling unit sections, connection hood, drain pipe, etc. may vary depending on the selected variant.

* The air handling unit is supplied without end connection panel if a duct accessory housed in an insulated casing will be connected.
The AHU can also be supplied with full face end connection panel (accessory).

Size	A	B	C	D	E	F	G	H	I	J	K	L	M	Weight, kg
070	1273,5	2637	1815	565	162	1000	1800	2640	320	625	418,5	4362	160	3322-3645
080	1273,5	2637	1815	565	162	1000	1800	2640	320	625	418,5	4362	160	3426-3785

10. GENERAL TECHNICAL DATA

Size	Airflow at SFPv 1.8 (m ³ /s)	Min. airflow (m ³ /s)	Cooling cap. (kW) ¹⁾	Heating cap. (kW) ²⁾	Refrigerant (kg)	Power supply	EER ¹⁾	COP ²⁾	Max. cooling cap. (kW) ³⁾
011	0.89	0,45	14.8 / 8.2	44.0 / 4.1	6	3 x 400V ±10%, +N +PE 16A	4.7	3.5	50,5
012	0.97	0,50	15.9 / 8.9	47.4 / 4.8	8	3 x 400V ±10%, +N +PE 25A	4.6	3.5	50,5
014	1.48	0,75	24.2 / 13.6	72.0 / 7.9	8	3 x 400V ±10%, +N +PE 25A	5.3	3.6	68,2
020	1.53	0,75	25.0 / 14.1	74.1 / 8.4	10	3 x 400V ±10%, +N +PE 25A	4.4	3.4	68,2
025	2.07	0,95	33.7 / 19.1	100.1 / 11.5	10	3 x 400V ±10%, +N +PE 25A	4.4	3.4	88,9
030	2.10	0,95	34.1 / 19.4	101.4 / 11.8	13	3 x 400V ±10%, +N +PE 32A	4.9	3.4	88,9
035	3.12	1.50	51.2 / 28.5	152.0 / 16.4	15	3 x 400V ±10%, +N +PE 50A	4.5	3.2	141,2
040	3.30	1.10	53.8 / 30.3	159.7 / 18.3	17.5	3 x 400V ±10%, +N +PE 50A	4.9	3.3	141,2
050	4.22	1.40	68.8 / 38.9	204.4 / 23.2	17.5	3 x 400V ±10%, +N +PE 63A	4.3	3.1	183,1
060	4.25	1.50	69.3 / 39.2	205.7 / 23.5	20	3 x 400V ±10%, +N +PE 63A	3.9	3.0	183,1
070	5.51	2.00	90.5 / 50.5	268.8 / 28.7	25	3 x 400V ±10%, +N +PE 63A	4.0	2.9	251,1
080	5.52	2.10	90.6 / 50.6	269.2 / 28.8	30	3 x 400V ±10%, +N +PE 80A	4.0	2.9	262,0

¹⁾ For an outdoor temperature of 26°C, 50% RH, extract air temperature of 22°C, supply air temperature 16°C. Cooling capacity: rotating heat exchange / coil HC.

²⁾ For an outdoor temperature of -20°C, 95% RH, extract air temperature of 22°C, supply air temperature 20°C. Heating capacity: rotating heat exchange / coil HC. Not RX/C.

³⁾ For an outdoor temperature of 34°C 50% RH, extract air temperature of 22°C, supply air temperature 16°C. Max. cooling output: rotary heat exchanger and HC coil at max. air flow.

Sizing

For correct sizing, we refer to our air handling unit selection program AHU Design.

11. WIRING DIAGRAM

For the wiring diagram, see the separate document.

12. DECLARATION OF CONFORMITY

For Declaration of Conformity, see our home page at www.swegon.com under Products & Services.

